

## VIP+ 5.1 ASHRAE-BESTEST

CASE 600FF CASE 900FF CASE 650FF CASE 950FF CASE 960

### Maximum annual hourly zone temperature

Minimum	64,9	41,8	63,2	35,5	48,9
Maximum	75,1	46,4	73,5	38,5	55,3
Average	67,7	43,7	66,1	36,6	50,5
VIP+	64,7	43,9	64,8	37,3	51,3

### Minimum annual hourly zone temperature

Minimum	-18,8	-6,4	-23	-20,2	-2,8
Maximum	-15,6	-1,6	-21	-17,8	6
Average	-17,6	-3,7	-22,4	-19,3	2,3
VIP+	-18,5	-6,3	-23	-20	0,7

### Average annual hourly zone temperature

Minimum	24,2	24,5	18	14	26,4
Maximum	27,4	27,5	20,8	15,3	30,5
Average	25,3	25,5	18,9	14,5	28,2
VIP+	24,4	24,3	18,6	14,2	27,1

VIP+ 5.1 ASHRAE-BESTEST

