

VIP+ 5.1

EN15265

Result

Klassificering	Max avvikelse %
A	5
B	10
C	15

Reference values	Heating		Cooling		Reference result	Heating	Klass	Cooling	Klass
	Test value	VIP+	Test value	VIP+					
Type 1(Light)	748	826	233,8	233	Type 1(Light)	7,94%	B	0,08%	A
Type 2 (Heavy)	722,7	793	200,5	188	Type 2 (Heavy)	7,61%	B	1,35%	A
Type 3(1+No gain)	1368,5	1457	43	47	Type 3(1+No gain)	6,27%	B	0,28%	A
Type 4(1+No shade)	567,4	678	1530,9	1407	Type 4(1+No shade)	5,27%	B	5,90%	B
Type5(1)	463,1	450	201,7	206	Type5(1)	1,97%	A	0,65%	A
Type6(2)	509,8	505	185,1	177	Type6(2)	0,69%	A	1,17%	A
Type7(3)	1067,4	1070	19,5	26	Type7(3)	0,24%	A	0,60%	A
Type8(4)	313,2	335	1133,2	1091	Type8(4)	1,51%	A	2,92%	A
Type9(5(1))	747,1	716	158,3	200	Type9(5(1))	3,43%	A	4,61%	A
Type10(6(2))	574,2	554	192,4	220	Type10(6(2))	2,64%	A	3,60%	A
Type11(7(3))	1395,1	1366	14,1	35	Type11(7(3))	2,07%	A	1,48%	A
Type12(8(4))	533,5	563	928,3	939	Type12(8(4))	2,02%	A	0,73%	A